



**OFFICE OF INSURANCE AND SAFETY FIRE COMMISSIONER**

COMMISSIONER OF INSURANCE • INDUSTRIAL LOAN COMMISSIONER • SAFETY FIRE COMMISSIONER

**Ralph T. Hudgens, Commissioner**

2 Martin Luther King Jr., Dr., Suite 920, West Tower, Atlanta, GA 30334

Phone: 404-656-9798 ♦ Fax: 770-344-4854 ♦ Email: pruddock@sfm.ga.gov



www.oci.ga.gov

HAZARDOUS MATERIALS  
GID-248B-SF JUN2015  
(same as SFD-29)

**FIRE SAFETY ANALYSIS WORKSHEET**

**FIRE SAFETY ANALYSIS WORKSHEET**

(To be completed by the local fire official)

I, \_\_\_\_\_ being the local authority having jurisdiction  
(Print Name) (Title)  
have completed an indepth Fire Safety Analysis of the proposed L.P. Gas Facility which will be located at \_\_\_\_\_  
in the County of \_\_\_\_\_.

During this Fire Safety Analysis I have determined the following:

**I.**

- (1) This proposed installation is located approx. \_\_\_\_\_ from the nearest important building(s) or property.
- (2) The response time of the nearest fire department to this facility is approx. \_\_\_\_\_ minutes. (Should be within 10 minutes)
- (3) An adequate water supply is provided at this location which would be able to provide at least 250 - 500 gpm per each tank which might be exposed to a single fire.  Yes  No

**II.**

- ( ) I have determined that regardless of fire department response time and water supply capabilities this proposed facility may be built due to its remote location which would pose little or no life safety hazards. In the event of fire at the facility the fire department and public safety personnel will limit their emergency forces to control of traffic and onlookers.
- ( ) I have determined that some hazard does exist to persons and/or other property at this proposed site. However, due to water supply and fire departments response time and capabilities this facility may be built.
- ( ) An unacceptable hazard exists at this proposed location due to one or all of the following reasons: heavily populated or congested area, container location(s), fire department response time, inadequate water supply, fire department capabilities, other. However, this facility may be built if the L.P. Gas facility provides the following: \_\_\_\_\_

---



---



---



---



---



---

- ( ) An unacceptable hazard exists at this proposed location and the L.P. Gas facility may not be built at this location.

Signature: \_\_\_\_\_ Title: \_\_\_\_\_ Date: \_\_\_\_\_